



City of Austin

Founded by Congress, Republic of Texas, 1839

Capital Contracting Office, PO Box 1088, Austin, Texas 78767 Telephone 512/974-7181

12/19/2018

TO: Offerors for Competitive Sealed Proposal solicitation

SUBJECT: Request for Competitive Sealed Proposals for the ABIA Consolidated Maintenance Facility, CSP Solicitation Number: CLMB329 – **CLARIFICATION # 1**

This clarification #1 is in response to questions received which warranted a clarification.

Clarification:

1. What is the well elevation on the pump stations?

Response: Refer to details C & D on Sheet C-UP-00-15 of Plans/Drawings Vol. 1 (p. 111 of 176) which indicates the bottom of the sump well is 84" beneath the indicated inlet flow line elevations. Per those same details top elevation is 1" to 3" above finish grade.

2. What is the procedure for approval of substitutions before the bid?

Response: Refer to specification Section 00700CSP, General Conditions, paragraph 6.2.4 for substitution procedures, which is only allowed after contract award. See also revised section 01 6000 Product Requirements in Addendum #2.

This document is for clarification purposes only. Please remember this solicitation is currently in a "No Contact" period and all inquiries should be directed to the appropriate contact persons listed in the solicitation. If you have questions regarding this process, please call Denice Parris at (512) 974-5608. You may also contact David Taylor, Project Manager at (512) 974-7132 for project related questions.

Sincerely,

Denice S. Parris
Capital Contracting Office, City of Austin
(512)974-5608